

Deutsche Akkreditierungsstelle GmbH

Annex to the Accreditation Certificate D-IS-17819-01-00 according to DIN EN ISO/IEC 17020:2012

Indefinite since: 10.12.2018

Date of issue: 20.08.2018

Holder of certificate:

**MPA Dresden GmbH
Fuchsmühlenweg 6F, 09599 Freiberg**

for its inspection body Type A

Inspections in the fields:

Inspections in the production department in the area of portable fire extinguishers, mobile fire extinguishers and fire extinguishing agents as to their compliance with certain requirements;

Inspections in the production department in the area of safety storage cabinets for determining their conformity to specific requirements;

Inspection in production for certifications within the European mandatory field (EU CPR) of products or product groups:

Gypsum products, wood-based materials, floor coverings, Roof coverings, rooflights, roof windows and ancillary products for purposes subjects to guidelines on fire behaviour, internal and external wall and ceiling finishes, pipes, tanks and ancillaries not contact with water intended for human consumption as well as energy, control and communication cables

This document is a translation. The definitive version is the original German annex to the accreditation certificate.

Abbreviations used: see last page

*The certificate together with its annex reflects the status at the time of the date of issue. The current status of the scope of accreditation can be found in the database of accredited bodies of Deutsche Akkreditierungsstelle GmbH.
<https://www.dakks.de/en/content/accredited-bodies-dakks>*

Annex to the Accreditation Certificate D-IS-17819-01-00

1. Inspections in the production department in the area of portable fire extinguishers, mobile fire extinguishers and fire extinguishing agents as to their compliance with certain requirements

VA IS1 FLGM
2014-01 Fire extinguishing agents and fire extinguishers - Inspections at the manufacturer location

based on:

DIN EN 3-7
2007-10 Portable fire extinguishers - Part 7: Characteristics, performance requirements and test methods

DIN EN 3-8
2007-02 +
Corrigendum 1
2008-01 Portable fire extinguishers - Part 8: Additional requirements to EN 3-7 for the construction, resistance to pressure and mechanical tests for extinguishers with a maximum allowable pressure equal to or lower than 30 bar

DIN EN 3-9
2007-02 +
Corrigendum 1
2008-01 Portable fire extinguishers - Part 9: Additional requirements to EN 3-7 for pressure resistance of CO2 extinguishers

DIN EN 3-10
2010-03 Portable fire extinguishers - Part 10: Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7

DIN EN 615
2009-08 Fire protection - Fire extinguishing media - Specifications for powders (other than class D powders)

DIN EN 1568-1
2018-05 Fire extinguishing media - Foam concentrates - Part 1: Specification for medium expansion foam concentrates for surface application to water-immiscible liquids

DIN EN 1568-2
2018-05 Fire extinguishing media - Foam concentrates - Part 2: Specification for high expansion foam concentrates for surface application to water-immiscible liquids

DIN EN 1568-3
2018-05 Fire extinguishing media - Foam concentrates - Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids

DIN EN 1568-4
2018-05 Fire extinguishing media - Foam concentrates - Part 4: Specification for low expansion foam concentrates for surface application to water-miscible liquids

-Translation-

Abbreviations used: see last page

Date of issue: 20.08.2018

Indefinite since: 10.12.2018

Annex to the Accreditation Certificate D-IS-17819-01-00

DIN EN 1866-1 2007-10 + Corrigendum 1 2008-01	Mobile fire extinguishers - Part 1: Characteristics, performance and test methods
DIN EN 1866-2 2014-07	Mobile fire extinguishers - Part 2: Requirements for the construction, pressure resistance and mechanical tests for extinguishers, with a maximum allowable pressure equal to or lower than 30 bar, which comply with the requirements of EN 1866-1
DIN EN 1866-3 2013-08	Mobile fire extinguishers - Part 3: Requirements for the assembly, construction and pressure resistance of CO ₂ extinguishers which comply with the requirements of EN 1866-1
DIN SPEC 14411 2013-07	Extinguishing aerosol dispenser
LM 01-01 2017-03	Testing of aqueous fire extinguishing agents Test specification of MPA Dresden

2. Inspections in the production department in the area of safety storage cabinets as to their compliance with certain requirements

VA IS2 SiSchr 2014-11	Safety storage cabinets – Inspections at the manufacturer location
based on:	
DIN 14470-1 2004-07	Fire safety storage cabinets - Part 1: Safety storage cabinets for flammable liquids
DIN 14470-2 2006-11	Fire safety storage cabinets - Part 2: Safety cabinets for pressurised gas cylinders
DIN EN 14727 2006-03	Laboratory furniture - Storage units for laboratories - Requirements and test methods

-Translation-

Abbreviations used: see last page

Date of issue: 20.08.2018

Indefinite since: 10.12.2018

Annex to the Accreditation Certificate D-IS-17819-01-00

3. Inspection in production for certifications within the European mandatory field (EU CPR) of products or product groups

VA IS5 Construction products – Inspections at the manufacturer
2018-05

for the products / product groups based on the following standards

Gypsum Products (1995/467/EC)

EN 13815 Fibrous gypsum plaster casts - Definitions, requirements and test
2006 methods

EN 14190 Gypsum board products from reprocessing - Definitions,
2014 requirements and test methods

Wood-based materials (1997/462/EC)

EN 13986 Wood-based panels for use in construction - Characteristics,
2004 + A1:2015 evaluation of conformity and marking

Floor coverings (1997/808/EC)

EN 13813 Screed material and floor screeds – Screed materials – Properties and
2002 requirements

EN 14041 Resilient, textile and laminate floor coverings - Essential
2004+AC:2006 characteristics

EN 14342 Wood flooring - Characteristics, evaluation of conformity and
2013 marking

EN 14904 Surfaces for sports areas - Indoor surfaces for multi-sports use –
2006 Specification

Roof coverings, rooflights, roof windows and ancillary products for purposes subjects to guidelines on
fire behaviour (1998/436/EC)

EN 14509 Self-supporting double skin metal faced insulating panels - Factory
2013 made products - Specifications

-Translation-

Abbreviations used: see last page

Date of issue: 20.08.2018

Indefinite since: 10.12.2018

Annex to the Accreditation Certificate D-IS-17819-01-00

Internal and external wall and ceiling finishes (1998/437/EC)

EN 438-7
2005 High-pressure decorative laminates (HPL) - Sheets based on thermosetting resins (usually called laminates) - Part 7: Compact laminate and HPL composite panels for internal and external wall and ceiling finishes

EN 13964
2014 Suspended ceilings - Requirements and test methods

EN 14509
2013 Self-supporting double skin metal faced insulating panels - Factory made products - Specifications

EN 14716
2004 Stretched ceilings - Requirements and tests methods

EN 15102
2007+A1:2011 Decorative wall coverings - Roll and panel form

Pipes, tanks and ancillaries not contact with water intended for human consumption (1999/472/EC)

EN 14800
2007 Corrugated safety metal hose assemblies for the connection domestic appliance using gaseous fuels

Energy, control and communication cables (2011/284/EU)

EN 50575
2014+A1:2016 Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements

Abbreviations used:

EU-BauPVO	EU-Bauproduktenverordnung (EU Construction Products Regulation)
DIN	Deutsches Institut für Normung e.V. (German Institute for Standardization)
EN	European Standard
LM	Test specification of MPA Dresden GmbH
VA IS	Inspection procedures of MPA Dresden GmbH

-Translation-

Abbreviations used: see last page

Date of issue: 20.08.2018

Indefinite since: 10.12.2018